



**ROCHELLE PARK PUBLIC SCHOOL
LEAD IN DRINKING WATER
FIRST & FLUSH DRAW SAMPLING REPORT**

PERFORMED FOR:

**ROCHELLE PARK PUBLIC SCHOOL
300 ROCHELLE AVENUE
ROCHELLE PARK, NJ 07662**

PERFORMED BY:

**WESTCHESTER ENVIRONMENTAL LLC
1248 WRIGHTS LANE
WEST CHESTER, PA 19380**

JUNE 2022



Results Report

Order ID: 2F02881

Westchester Environmental 1248 Wrights Lane West Chester, PA 19380	Project: Rochelle Park Public School 300 Rochelle Ave Rochelle Park, NJ 07662
Attn: Noel Abraham	Regulatory ID:

Sample Number: 2F02881-01	Site: RP-K-FP-F	Sample ID: KITCHEN PREP SINK							
Collector: CMP	Collect Date: 06/04/2022 11:27 am	Sample Type: Grab							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:03	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-02	Site: RP-K-KC-L-F	Sample ID: KITCHEN PREP SINK							
Collector: CMP	Collect Date: 06/04/2022 11:28 am	Sample Type: Grab							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:05	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-03	Site: RP-K-KC-R-F	Sample ID: KITCHEN PREP SINK							
Collector: CMP	Collect Date: 06/04/2022 11:29 am	Sample Type: Grab							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:07	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-04	Site: RP-TL-RM121-F	Sample ID: TEACHERS LOUNG ROOM 121							
Collector: CMP	Collect Date: 06/04/2022 11:30 am	Sample Type: Grab							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:08	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-05	Site: RP-WC-O/S RM110-F	Sample ID: WATERCOOLER O/S ROOM 110							
Collector: CMP	Collect Date: 06/04/2022 11:31 am	Sample Type: Grab							
Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By

Metals

Lead	22.0	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:10	MKS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 06/23/2022 6:56 pm 2F02881
 STL_Results Revision #2.0 Effective: 04/20/2022

SUBURBAN TESTING LABS





SUBURBAN TESTING LABS

Sample Number: 2F02881-06	Site: RP-WC-O/S RM108-F	Sample ID: WATERCOOLER O/S 108
Collector: CMP	Collect Date: 06/04/2022 11:32 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	26.2	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:11	MKS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-07	Site: RP-DW-RM105-F	Sample ID: ROOM 105
Collector: CMP	Collect Date: 06/04/2022 11:33 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:13	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-08	Site: RP-DW-RM104-F	Sample ID: ROOM 104
Collector: CMP	Collect Date: 06/04/2022 11:34 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.79	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:15	MKS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-09	Site: RP-DW-RM102-F	Sample ID: ROOM 102
Collector: CMP	Collect Date: 06/04/2022 11:35 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.32	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:19	MKS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-10	Site: RP-DW-RM106-F	Sample ID: ROOM 106
Collector: CMP	Collect Date: 06/04/2022 11:36 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:21	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-11	Site: RP-BF-O/S RM 211-F	Sample ID: WATERCOOLER O/S 211
Collector: CMP	Collect Date: 06/04/2022 11:37 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:23	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 06/23/2022 6:56 pm 2F02881
 STL_Results Revision #2.0 Effective: 04/20/2022

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



PA DEP # 06-00208
 NJDEP# PA081



SUBURBAN TESTING LABS

Sample Number: 2F02881-12	Site: RP-BF-O/S RM 221-F	Sample ID: WATERCOOLER O/S 221
Collector: CMP	Collect Date: 06/04/2022 11:38 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:24	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-13	Site: RP-BF-O/S GYM-F	Sample ID: BOTTLE FILL O/S GYM ENTERANCI
Collector: CMP	Collect Date: 06/04/2022 11:39 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:26	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-14	Site: RP-BF-O/S RM 323-F	Sample ID: BOTTLE FILL O/S ROOM 323
Collector: CMP	Collect Date: 06/04/2022 11:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:27	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-15	Site: RP-DW-RM101-F	Sample ID: ROOM 101
Collector: CMP	Collect Date: 06/04/2022 11:41 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:29	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-16	Site: RP-DW-RM107-F	Sample ID: ROOM 107
Collector: CMP	Collect Date: 06/04/2022 11:42 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:31	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2F02881-17	Site: RP-BF-O/S RM 109-F	Sample ID: BOTTLE FILL O/S ROOM 109
Collector: CMP	Collect Date: 06/04/2022 11:43 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/22/22	MKS	06/22/22 19:32	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

Report Generated On: 06/23/2022 6:56 pm 2F02881
STL_Results Revision #2.0 Effective: 04/20/2022

SUBURBAN TESTING LABS

1037F MacArthur Road, Reading, PA 19605 Phone: 610-375-TEST Fax: 610-375-4090 suburbantestinglabs.com



PA DEP # 06-00208
NJDEP# PA081



SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Ryan F Knerr
Project Manager II

Report Generated On: 06/23/2022 6:56 pm
STL_Results Revision #2.0

2F02881
Effective: 04/20/2022





2F02881
Ryan F Knerr



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605
610-376-TEST - Fax: 610-376-4090 - suburbantestinglabs.com

TAT (Check One)

Standard

24hr

48hr

72hr

Handwritten initials

Client Name:	Westchester Environmental LLC.	Project Name:	Rochelle Park Public School
Address:	1248 Wrights Lane	Address:	Rochelle Park Public School
	West Chester, PA 19380		300 Rochelle Ave, Rochelle Park, NJ 07662
Contact Name:	Noel Abraham	Payment / P.O. Info:	
		Email:	nabraham@westchesterenvironmental.com

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
	(10) 2 Some P-F H1043											
Flush	RP-K-FP-F	06/04/22	11:27 AM	CMP	001	Pb EPA 200.8	1	PW	G	P	H	Kitchen Prep Sink
Flush	RP-K-KC-L-F	06/04/22	11:28 AM	CMP	002	Pb EPA 200.8	1	PW	G	P	H	Kitchen Prep Sink
Flush	RP-K-KC-R-F	06/04/22	11:29 AM	CMP	003	Pb EPA 200.8	1	PW	G	P	H	Kitchen Prep Sink
Flush	RP-TL-RM121-F	06/04/22	11:30 AM	CMP	004	Pb EPA 200.8	1	PW	G	P	H	Teachers Lounge Room 121
Flush	RP-WC-O/S RM110-F	06/04/22	11:31 AM	CMP	005	Pb EPA 200.8	1	PW	G	P	H	WaterCooler o/s Room 110
Flush	RP-WC-O/S RM108-F	06/04/22	11:32 AM	CMP	006	Pb EPA 200.8	1	PW	G	P	H	WaterCooler o/s Room 108
Flush	RP-DW-RM105-F	06/04/22	11:33 AM	CMP	007	Pb EPA 200.8	1	PW	G	P	H	Room 105
Flush	RP-DW-RM104-F	06/04/22	11:34 AM	CMP	008	Pb EPA 200.8	1	PW	G	P	H	Room 104
Flush	RP-DW-RM102-F	06/04/22	11:35 AM	CMP	009	Pb EPA 200.8	1	PW	G	P	H	Room 102
Flush	RP-DW-RM106-F	06/04/22	11:36 AM	CMP	010	Pb EPA 200.8	1	PW	G	P	H	Room 106

Relinquished by: *[Signature]*

Date: 06/06/22
Time: 11:15

Received By: **3**
Amy Dawinny Coopers

Date: 6/7/22
Time: 1:35
Temp °C: *Cooper*
Acceptable N

Relinquished by: **3**
Amy Dawinny Coopers

Date: 6/7/22
Time: 1:53
Temp °C: *Cooper*
Acceptable N

Received in Lab By:

CTB (10)

Date: 6-7-22
Time: 1453
Temp °C: 22°C
Acceptable N

Sample Location	Matrix	Bottle Type Key
Classroom	NEW - Non-Flammable	Plastic
Office	NEW - Non-Flammable	Glass
Industrial	NEW - Non-Flammable	Other
Water	NEW - Non-Flammable	Preservative Key
Soil	NEW - Non-Flammable	Plastic
Sludge	NEW - Non-Flammable	Plastic
Asbestos	NEW - Non-Flammable	Plastic
Lead	NEW - Non-Flammable	Plastic
Mercury	NEW - Non-Flammable	Plastic
PCB	NEW - Non-Flammable	Plastic
PAH	NEW - Non-Flammable	Plastic
Other	NEW - Non-Flammable	Plastic



2F02881
Ryan F Knerr



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19805
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT (Check One) Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Rochelle Park Public School		
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Rochelle Park Public School		
	West Chester, PA 19380	Email:	nabraham@westchesterenvronmental.com		300 Rochelle Ave, Rochelle Park, NJ 07662		
Contact Name:	Noel Abraham			Payment / P.O. Info:			

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
	(7) 250ML PTHHOS											
Flush	RP-BF-O/S RM 211-F	06/04/22	11:37 AM	CMP	011	Pb EPA 200.8	1	PW	G	P	H	WaterCooler o/s 211
Flush	RP-BF-O/S RM 221-F	06/04/22	11:38 AM	CMP	012	Pb EPA 200.8	1	PW	G	P	H	WaterCooler o/s 221
Flush	RP-BF-O/S GYM-F	06/04/22	11:39 AM	CMP	013	Pb EPA 200.8	1	PW	G	P	H	Bottle Fill o/s Gym Entrance
Flush	RP-BF-O/S RM 323-F	06/04/22	11:40 AM	CMP	014	Pb EPA 200.8	1	PW	G	P	H	Bottle Fill o/s Room 323
Flush	RP-DW-RM101-F	06/04/22	11:41 AM	CMP	015	Pb EPA 200.8	1	PW	G	P	H	Room 101
Flush	RP-DW-RM107-F	06/04/22	11:42 AM	CMP	016	Pb EPA 200.8	1	PW	G	P	H	Room 107
Flush	RP-BF-O/S RM 109-F	06/04/22	11:43 AM	CMP	017	Pb EPA 200.8	1	PW	G	P	H	Bottle Fill o/s Room 109

Relinquished by:

Received By:

Relinquished by:

Received in Lab By:

Date: 06/06/22
Time: 11:15

Date: 6/7/22
Time: 12:55
Temp °C:
Acceptable N
Coda

Date: 6-7-22
Time: 1453
Temp °C: 22°C
Acceptable N

Sample Conditions	Matrix Key	Bottle Type Key
<input checked="" type="checkbox"/> 20°C <input checked="" type="checkbox"/> 25°C <input type="checkbox"/> 30°C <input type="checkbox"/> 35°C <input type="checkbox"/> 40°C <input type="checkbox"/> 45°C <input type="checkbox"/> 50°C <input type="checkbox"/> 55°C <input type="checkbox"/> 60°C <input type="checkbox"/> 65°C <input type="checkbox"/> 70°C <input type="checkbox"/> 75°C <input type="checkbox"/> 80°C <input type="checkbox"/> 85°C <input type="checkbox"/> 90°C <input type="checkbox"/> 95°C <input type="checkbox"/> 100°C	<input checked="" type="checkbox"/> H ₂ O <input type="checkbox"/> Urine <input type="checkbox"/> Blood <input type="checkbox"/> Saliva <input type="checkbox"/> Hair <input type="checkbox"/> Nail <input type="checkbox"/> Tissue <input type="checkbox"/> Bone <input type="checkbox"/> Other	<input type="checkbox"/> 100ml <input type="checkbox"/> 250ml <input type="checkbox"/> 500ml <input type="checkbox"/> 1L <input type="checkbox"/> 2L <input type="checkbox"/> 4L <input type="checkbox"/> 6L <input type="checkbox"/> 12L <input type="checkbox"/> 24L <input type="checkbox"/> 48L <input type="checkbox"/> 96L <input type="checkbox"/> Other